

कार्यालय नगर परिषद, अलवर (राज0)


क्रमांक:- जनस्वास्थ्य / 2023 / 3293

दिनांक: 02/06/2023

प्रमाण-पत्र

प्रमाणित किया जाता है कि दिनांक 02.06.2023 को आर्य पब्लिक स्कूल, ब्लॉक-ए, मालवीय नगर, अलवर का निरीक्षण किया गया। निरीक्षण के दौरान विद्यालय परिषर में सैनिटेशन व्यवस्था, स्वच्छ पेयजल व्यवस्था, डस्टबीन व्यवस्था एवं कमरे उपयुक्त रोशनीयुक्त पाये गये व विद्यालय परिषर की साफ-सफाई की व्यवस्था उचित व व्यवस्थित मिली।


Principal
Arya Public School
Malviya Nagar, ALWAR


मुख्य सफाई निरीक्षक
नगर परिषद, अलवर



OFFICE OF THE SENIOR CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, ALWAR

Lab/Tech/(Private)/2023-24/ 140

Dated: 23.5.23

EXAMINATION REPORT OF THE PRIVATE WATER SAMPLES

Issued To,

Arya Public Sr.Sec.School
A-Block, Malviya Nagar
Alwar

District: ALWAR
Block/City: Alwar

Ref ID: 28		Lab Sample No.: 28		
Reference :Your Letter No.: 0		Source: TW		
Reference Dated: 17.05.23		Source Location: A-Block, Malviya Nagar		
Date of Receipt: 17.05.23		Habitatation/Ward No.: Alwar		
Name of Sample Taker: Mr.Deendayal		Village/Colony/Town: Alwar		
Desig. of Sample Taker: 0		Gram Panchayat/City Area: Alwar		
GA-55 Book No.: 093407		Date of Collection: 17.05.23		
GA-55 Receipt No.: 0089		Date of Examination: 17.05.23		
Amount in Rs.: 297.00		Amount Deposited for: Chem/Bact Testing of Water Sample		
IS-10500:2012				
Test Parameters		Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	Test Values of Samples
1	pH	6.5 to 8.5	No Relaxation	7.1
2	Turbidity(NTU)	5	15	Clear
3	Colour (Hazen Unit)	1	5	None
4	Odour	Unobjectionable	-	None
5	Total Alkalinity (as CaCO ₃) mg/L	200	600	50
6	Total Hardness (as CaCO ₃) mg/L	300	600	100
7	Calcium (as Ca++) mg/L	75	200	24
8	Magnesium (as Mg++) mg/L	30	100	10
9	Chloride (as Cl) mg/L	600	1000	40
10	Sulphate (as SO ₄ ⁻²) mg/L	200	400	0
11	Nitrates (as NO ₃ ⁻) mg/L	45	No Relaxation	18
12	Fluoride (as F ⁻) mg/L	1.00	1.50	0.48
13	Total Dissolved Solids (TDS) mg/L	500	2000	242
14	Residual Chlorine (mg/L)	0.20	1.00	-
15	Total Coli Form/100 ml.	NIL/100 ml.	NIL/100 ml.	53
16	E-Coli/ 100 ml.	NIL/100 ml.	NIL/100 ml.	-

Lab/Tech/(Private)/2023-24/
Copy to:

- 1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.
- 2
- 3

Nancy
Principal
Arya Public School
Malviya Nagar, Alwar

Senior Chemist
PHED, Lab, Alwar
Dated:

Senior Chemist
Save Water Save Life

Safe Water is Life